

Village of Oil Springs

Tender: Stormwater Sewer Replacement

Closing Date: Friday September 6th, 2019, 12 noon

Addendum Number 1 – September 1, 2019

This addendum will form a part of the tender documents for the above-noted tender and shall be read in conjunction therewith. This addendum will take precedence over all requirements of the original tender documents and any addenda issued previously. Bidders shall acknowledge receipt of this addendum with the inclusion of the ADDENDA FORM.

1. Form of Tender Item 1.8 and 2.14 – Restoration Asphalt Roadway.
The required thickness of asphalt for these items shall be:
50mm HL3
80mm HL8
These layers should match existing.